



### Hazardous Materials Segregation Requirements

Class	1.1	2.1	2.2	2.3	3.1	4.1	4.2	4.3	5.1	5.2	6.1	8
1.1		C	C	C	C	C	C	C	C	C	C	C
2.1	C			C	B	B	C	B	C	C	B	B
2.2	C			C	A	A	B	A	A	B	A	A
2.3	C	C	C		C	C	C	C	C	C	C	C
3.1	C	B	A	C		B	B	B	C	C	B	A
4.1	C	B	A	C	B		B	B	C	C	B	A
4.2	C	C	B	C	B	B		B	C	C	B	A
4.3	C	B	A	C	B	B	B		C	C	B	B
5.1	C	C	A	C	C	C	C	C			B	B
5.2	C	C	B	C	C	C	C	C	B		C	B
6.1	C	B	A	C	B	B	B	B	B	C		A
8	C	B	A	C	A	A	A	B	B	B	A	

Note: The separation or segregation of 2 different classes of hazardous materials is indicated by the code shown at the intersection of the vertical column corresponding to one class and the horizontal row corresponding to the other class.

- A : Must be separated by at least 3 m
- B : Must be separated by at least 5 m
- C : Must not be stored in the same room or space. Minimum separation of 10 m between storage areas.